GOVERNMENT OF ANDHRA PRADESH
ABSTRACT

Water Resources Department - Permission to draw 4,90,000 litres of water per day (0.2 cusecs/day) at Km 24.750 of Guntur Channel during the canal running Period for Sri Sringeri Sarada Rajarajeswari Charitable Hospital, Pedakakani, Guntur District - Permission- Accorded.

WATER RESOURCES (WRG-GRC) DEPARTMENT

G.O.RT.No. 810 Dated: 21-12-2017

Read the following:-

1. From the Project in charge, Sri Sringeri Sharada Rajarajeswari Charitable Hospital, "Y" Junction, Pedakakani (V) & (M), Guntur District , letter dated Nil.
2. Govt. Memo.No.100619/WRG-GRC/2015-1, dated 23.12.2015.
3. From the Engineer-in-Chief (Irrigation), W.R. Dept., A.,P., Vijayawada, Lr.No.ENC(I)/DCEDW/OT7/AEE20/Water Drawl/2016 dated 07.10.2017.

@@@

ORDER:

In the reference 1st read above, the Project in Charge, Sri Sringeri Sharada Rajarajeswari Charitable Hospital, Guntur has requested the Government for according permission to draw 4,90,000 litres of water per day from Guntur Channel during the flow period for the purpose of drinking and to provide other amenities to the patients, staff etc. as mentioned below:

S.No.	Description	No. of Persons	Water Requirement per head	Total Quantity in Litres/day
(i)	Patients and their Attendants	1000 Nos	135 Litres each	1,35,000
(ii)	Residents/ Non-Residents staff in Quarters	1000 Nos	100 Litres each	1,00,000
(iii)	For Devotees	1000 Nos	50 Litres each	50,000
(iv)	For Cows	200 Nos	350 Litres each	70,000
(v)	For Green fields for Cows			1,35,000
	Total			4,90,000

2. In the reference 3rd read above, the Engineer-in-Chief (Irrigation) Water Resources Department, A.P., Vijayawada has furnished report and requested the Government to accord permission to draw 4,90,000 litres of water per day (0.2 cusecs/day) at Km 24.750 of Guntur Channel during the canal running Period for Sri Sringeri Sarada Rajarajeswari Charitable Hospital, Pedakakani, Guntur District, subject to fulfilling certain conditions.

3. After careful examination of the matter, Government, hereby, accord permission to draw 4,90,000 litres of water per day (0.2 cusecs/day) at Km 24.750 of Guntur Channel during the canal running Period for Sri Sringeri Sarada Rajarajeswari Charitable Hospital, Pedakakani, Guntur District for the purpose of drinking and to provide other amenities to the patients, staff etc. as mentioned below, subject to the following conditions:

S.No.	Description	No. of Persons	Water Requirement per head	Total Quantity in Litres/day
(i)	Patients and their Attendants	1000 Nos	135 litres each	1,35,000
(ii)	Residents/ Non-Residents staff in Quarters	1000 Nos	100 litres each	1,00,000
(iii)	For Devotees	1000 Nos	50 litres each	50,000

(iv)	For Cows	200 Nos	350 litres each	70,000
(v)	For Green fields for Cows			1,35,000
	Total			4,90,000

Conditions:

a) The society should lay the required pipe line through their own lands at their own cost.

b) The Society should erect the pump house on their own land at their own cost.

c) The Society should install intake pipeline and construction of a sluice at suitable location of Guntur channel System at their own cost. The location and work should be under supervision of department officers and should pay to the department the cost of its restoration to original standards. The Society should also install suitable measuring instrument at the pumping station to record the intake from the Guntur Channel and the same should be made available for inspection of the Department.

d) The society should enter into necessary departmental agreement. The water charges are to be paid as fixed by the Government from time to time.

e) The Department in no way be responsible for Non Supply of water at source due to various reasons which are beyond the control of the Department.

f) For allowing drawl during Canal Running Period i.e Generally from July to November only. In the remaining period the agency has to make their own arrangement.

g) Water will be supplied depending on availability during canal operation period only and the Agency cannot claim Water arrangement.

h) The Raw water from the canal source only will be supplied/allowed to draw. The responsibility for Treatment etc. lies with Agency only.

i) Violation of any of the conditions mentioned shall be entitled for the cancellation of permission granted for drawl of water without any Notice.

4. The Engineer-in-Chief (Irrigation), Water Resources Department, A.P., Vijayawada, shall take necessary further action in the matter.

(BY ORDER AND IN THE NAME OF THE GOVERNOR OF ANDHRA PRADESH)

SHASHI BHUSHAN KUMAR
SECRETARY TO GOVERNMENT

To
The Engineer-in-Chief (Irrigation), Water Resources Department, A.P., Vijayawada.
Copyto:
The Project in Charge, Sri Sringeri Sharada Rajarajeswari Charitable Hospital, Guntur, through ENC (Irrigation), Vijayawada.
The P.S to Hon'ble Minister for Water Resources Management.
The P.S to Secretary to Government, Water Resources Department.
SC/SF.

//FORWARDED :: BY ORDER//

SECTION OFFICER